

Visualize a published system sheet

FNP system

FNP number : 1162
Index FNP : S002
Last publication : 31/07/2026
State : PUBLISHED
Supplier : MAESTRIA
Total thickness : 100µm

public comment EN : 30/07/2026 - Extension of the FNP1162 qualification as PIC105, in addition of PIA PIB and PID 104 105 codifications, and up to 350°C. This coating system is published based on the RRC-A accident conditions only. Severe accident evaluation RRC-B will be performed later. 17/12/2025 - First publication of FNP1162 for PIA PIB and PID 104 105 codifications up to 350°C.

intern comment : 11/06/2026 - Publication anticipée du dossier en PIC105 afin de respecter les délai Projet de juin 2026. La publication complète est en cours et sera terminée pour T3 2026. 30/07/2026 : Ajout de la codification PIC 104/105. Il faudra ajouter le rapport de répétabilité (essais en cours) 17/12/2025 - Première publication anticipée. Publication complète à prévoir lors de l'extension de qualification en PIC104 105.

Utilities type : PARC NUCLEAIRE

Technical sheet : [FT EN 1162 Juillet 2026 R08.pdf](#)

Codifications published

Série	Groupe
PIC	104
PIC	105

Coat list

Coat number	Product name	Thickness	Nature of the binder	Type of phase	Proportion of solvent
1	STRIATHERM 350 V01 PRIMER	50 µm	Silicone	SV	8
2	STRIATHERM 350 V01 FINISH	50 µm	Silicone	SV	19
3	-----				
4	DILUANT 68-69 V01		Diluant		